# POOL / SPA SUBMITTAL REQUIREMENTS

As required by Bureau Veritas North America, Inc.

## ALL INFORMATION MUST BE FILLED IN, CHECKED OR MARKED N/A

Appl	ication
Loca	l Municipal Approval
	Plan of pool/spa location showing any overhead lines
1 cop	by of manufacturer specifications and plans (must be at site)
The followi	ng items, views and details shall appear on all plans:
4	Leasting of goal words have that any supplied armine automas a shipe and 00 FL
1.	Location of pool must be so that any overhead service entrance cables are 22.5'
	from the water level in any direction. If installing a diving board or platform a distance of 14.5' must be maintained.
2.	
Z.	If in-ground pool, consideration for any underground utilities should be taken.
	No non-pool related underground wire within 5' of pool wall unless in approved conduit.
3.	Pool wiring:
3.	a. Feed wires and branch circuit wires need to be installed in conduit. NM
	(romex) allowed indoors only in residential.
	b. Conduit must be of the following type: RMC, IMC, LFNMC, RNC
4.	Bonding:
<del>-</del> .	a. All metal parts of structure & equipment must be bonded
	b. Exception: isolated parts < 4" in any dimension and do not penetrate
	the pool structure < 1"
	c. Bonding with a 8 AWG or larger conductor
5.	Grounding:
0.	a. Grounding conductors must be insulated
	b. No splices in conductors must land in terminals
6.	Lighting:
01	a. Underwater Wet-Niche:
	1. Installed where top of fixture lens is not less than 18" below
	water line
	2. Bonded and secured to shell requiring a tool for fixture removal
	3. Low voltage lines from UL listed transformer separate from line
	voltage
	4. Over 15 V must be GFCI protected
	5. Connections in Wet-Niche must be potted
	6. Metal parts in contact with pool water need to be corrosion-
	resistant
	7. Junction boxes for pools must be UL listed for use
	b. Dry-Niche:
	1. Provided with means for drainage of water
	2. One equipment-grounding conductor for each conduit entry
	c. No-Niche:
	1. UL listed for use
	2. Installed in forming shells connected for each conduit bracket

**Receptacles and Equipment Locations:** 7.

a. Receptacles for circulation and sanitation systems of pools shall be permitted to be located between 5' and 10' from pool wall and be a single rec. GFCI protected with ground and be of a locking type.

b. Permanently installed pools require a receptacle at least 10' but no more than 20' from pool wall

c. All exterior receptacles within 20' of pool walls need to be GFCI protected

d. An accessible disconnecting means for all equipment except lighting shall be located within site of equipment and not less than 5' from pool wall Lighting Outlets:

a. Existing lights less than 5' from pool wall and at least 5' above the water level need to be GFCI protected

b. New installation above the pool or within 5' of pool wall need installed at least 12' above the water line

c. Indoors lights with a totally enclosed fixture or identified for use can be 7'6" above the water if GFCI protected

d. Switches other than ones UL listed need to be at least 5' from pool wall 9. Entrapment protection:

a. All pool and spa suction outlets shall conform to ANSI/ASME A112.19.8M or be a drain grate of at least 12" X 12" or larger or an approved channel drain

### SPAS AND HOT TUBS

10. Spas and hot tubs follow same rules as pools except for:

a. Factory assembled units can connect to power source with a 15" cord to a GFIC outlet

b. Bond all metal parts within 5' of spa or hot tub

c. GFCI protection to spa or hot tub not required if pumps, heaters, lights and other electrical equipment is protected by self contained GFCI UL listed from factory

d. No wall switches or appliances within 5' of hot tub or spa

e. Indoor locations: Light fixtures permitted less than 7' 6" over spa or hot tub if GFCI protected, enclosed with glass or plastic lens, no exposed metal parts and listed for damp locations.

#### **REQUIRED BARRIERS**

11. Barriers are designed to provide protection against potential drowning by restricting access to swimming pools, hot tubs and spas:

a. The barrier must be at least 48" to the top above the finish grade

b. Openings in barrier shall not allow a 4" diameter sphere to pass through

c. Access gates for pedestrians shall have a self locking device and be of a self closing type

d. The release mechanism for the gate must be at least 54" from the bottom of the gate or be located at least 3" below the pool side of the top of the gate

e. If a wall of a dwelling serves as part of the barrier all doors that directly access the pool need to be equipped with an audible alarm

f. Where an above ground pool serves as the barrier the ladder or steps need to be capable of being locked, secured or removed to prevent access

8.

\_\_\_\_\_g. Barriers shall be constructed and located away from structures, equipment or similar objects to prevent them from being used to climb on or over the barriers

h. <u>Barrier exceptions – hot tubs or spas with a safety cover complying</u> with ASTMF 1346 shall be exempt from these provisions.

#### \_\_12. Decks:

a. Decks built 30" high above grade require guards

\_\_\_\_\_b. Plans for deck need to be submitted for approval at time of permit application

\_\_\_\_c. Deck footing must be a minimum of 36" deep

\_\_\_\_d. Access to decks around pools must meet above barrier requirements

\_\_\_\_\_e. Decks cannot cantilever on above ground pool walls without proof from the manufacturer that the pool is capable of supporting the deck

13. Portable or storable pools:

\_\_\_\_\_a. Cord connected pumps shall have a double insulated cord and ground that grounds all internal non-accessible metal parts

\_\_\_\_b. Electrical equipment needs protected by GFCI circuit

\_\_\_\_\_c. Lights for storable pools need to be UL listed with no exposed metal parts

I have read and understand the above requirements for the installation of swimming pools and/or spas. By signing this document I agree to install my pool/spa in accordance with the Pennsylvania Uniform Construction Code Law.

**Print Name** 

Signature

Date

#### THIS COMPLETED FORM MUST BE TURNED IN WITH PLANS